

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**Hilscher Gesellschaft für
Systemautomation mbH**

Rheinstr. 15, 65795 Hattersheim, Germany

Reference Implementation

The tested device is a reference implementation of a Technology Component. Any device using this implementation still needs to be certified with their own VendorID, DeviceID and GSD file.

the Certificate No: **Z11514** for the PROFINET IO Device:

Model Name: COMX 51XX-RE/PNS
 Revision: SW/FW: 3.11.0.0; HW: 2
 Identnumber: 0x011E; 0x0117
 GSD: GSDML-V2.33-HILSCHER-COMX 51XX-RE PNS-20161024.xml
 DAP: DIM 24, 0x00002081

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.33
<input checked="" type="checkbox"/> Conformance Class	C
<input type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	V2.33.2 with annex spirta
<input checked="" type="checkbox"/> Tester	an testlabs, Prague, Czech Republic PN000-196

This certificate is granted according to the document:

“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by November 04, 2019 the certificate is valid for life.

Karlsruhe, December 06, 2016


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)

(K.-P. Lindner)